

State Water Resources Control Board

July 20, 2018

(Via email and Certified Mail)
CERTIFIED MAIL
NO. 7017 2680 0000 6195 9227

Mr. Shea Eccleston
Senior Public Works Manager
City of Glendale Public Works
541 West Chevy Chase Drive
Glendale, California 91204
seccleston@glendaleca.gov

SUBJECT: NOTICE OF VIOLATION - NO FURTHER ACTION REQUIRED; UNDERGROUND STORAGE TANK SYSTEM AT GWP PERKINS BUILDING, 141 NORTH GLENDALE AVENUE, GLENDALE

Dear Mr. Eccleston:

As part of an initiative by the State Water Resources Control Board (State Water Board) to ensure compliance at government-owned and/or operated underground storage tank (UST) facilities in California, the State Water Board staff inspected the UST at your facility on June 26, 2018, pursuant to authority under Health and Safety Code (H&SC), chapter 6.7, section 25289.

The State Water Board has identified the following violations pursuant to H&SC, chapter 6.7, and California Code of Regulations (CCR), title 23, chapter 16:

No.	Violation	Tank	Start Date	Stop Date	Regulation
1	Failure to Maintain Overfill Prevention Requirements – The visual alarm failed when tested. Verdugo Testing Company corrected this violation at the time of the inspection.	Diesel	June 26, 2018	June 26, 2018	23 CCR 2635 (b)(2)(A)

To our knowledge, the violation above has been corrected. Therefore, no further action is required at this time.

If you have any questions, please contact me at (916) 341-5551, or by email at amantha.henkel@waterboards.ca.gov.

Sincerely,



Amantha Henkel
Senior Environmental Scientist
UST Enforcement Unit
Office of Enforcement

cc: See next page.

Office of Enforcement | 801 K Street, Suite 2300 | Sacramento, CA 95814 | 916.341.5272

FELICIA MARCUS, CHAIR | EILEEN SOBECK, EXECUTIVE DIRECTOR

cc: *(via email only)*

Mr. Michael Lunsford
Assistant Environmental Technician
City of Glendale Public Works
mlunsford@glendaleca.gov

Ms. Lucy Varpetian
Senior Assistant City Attorney
City of Glendale
lvarpetian@glendaleca.gov

Mr. Gevorg Nazaryan
Fire Inspector
Glendale City Fire Department
gnazaryan@glendaleca.gov

Mr. Jovan Diaz
Principal Fire Environmental Safety Specialist
Glendale City Fire Department
jodiaz@ci.glendale.ca.us

Mr. Adam Levitan
Deputy Attorney General
Office of the Attorney General
adam.levitan@doj.ca.gov

Mr. David Boyers
Assistant Chief Counsel
Office of Enforcement
david.boyers@waterboards.ca.gov